

**Certificate of constancy of performance**  
**DoP: (N°/Number): 526-002**

---

1. Unique code of the product type:

**GS526 (Smoke alarm detector)**

2. Usage:

**According to EN 14604: 2005 / AC: 2008 Table ZA2: Smoke alarm detector for fire protection.**

3. Manufacturer:

**Siterwell Electronics Co., Limited**  
**No.666 Qingfeng Road, Jiangbei District,**  
**Ningbo, Zhejiang Province, 315034 China**  
**Tel: 0086-574-87729316 Mail: sales@china-siter.com**

4. Authorized representative:

**Sebastian Sonntag**  
**SEBSON**  
**Gernotstr.17**  
**44319 Dortmund**  
**Deutschland**

5. System for the assessment and verification of performance:

**System 1**

6. a) Harmonized standard: **EN 14604:2005/AC:2008**

· Notified body: **NB 0786 Vds Schadenverhütung GmbH**

7. Services rendered:

Essential characteristics	Performance	Harmonised technical specification
Nominal activation conditions/ Sensitivity. Response delay (response time) and Performance under fire conditions	PASS	EN 14604:2005/AC:2008
Operational reliability	PASS	
Tolerance to supply voltage	PASS	
Durability of operational reliability and response delay; temperature resistance	PASS	
Durability of operational reliability; vibration resistance	PASS	
Durability of operational reliability; humidity resistance	PASS	
Durability of operational reliability; corrosion resistance	PASS	
Durability of operational reliability; electrical stability	PASS	

The performance of the above product corresponds to the declared performance. The above manufacturer is solely responsible for the preparation of the service declaration in accordance with Regulation (EU) No 305/2011.

Signed for the manufacturer and on behalf of the manufacturer of:

Sebastian Sonntag  
SEBSON

Dortmund, 5.7.2018  
Place and date of issue

S. S. [Signature]  
Signature